IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

LEVELS OF HALOACETIC ACIDS ABOVE DRINKING WATER STANDARDS FOR LAKE SANTEE RWWD

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. The results of regular monitoring are an indicator of whether or not our drinking water meets EPA's health standards. The results that we received for Haloacetic Acids for the last monitoring period show that our system currently exceeds the standard(s), or Maximum Contaminant Level(s) (MCL). The MCL for Haloacetic Acids is 60 ug/L. As of 6/30/2015, a locational running annual average is 65.1 ug/L.

What should I do?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

Some people who drink trihalomethanes (THM) in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer. Some people who drink water containing haloacetic acids (HAA) in excess of the MCL over many years may have an increased risk of getting cancer.

What Happened? What is being done? (Explain below the reason, corrective action, and when the system expects to be or was back in compliance.)

When the sample was taken in May, we were bypassing our granular activated carbon tanks due to an issue with the carbon. Carbon removes organic matter from the water. When organic matter comes in contact with chlorine, haloacetic acids are formed.
We are currently working with our carbon manufacturer to resolve the issue. We expect the issue to be resolved in the next sixty days. As of August we are back in compliance.

We anticipate resolving the problem within In Compliance as of August.
estimated time frame

For more information, please contact Brandon Litmer at
name of contact

(812)527-2943 or 13 SW Wrenn Parkway, GREENSBURG,IN 47240.
phone number *mailing address*

Please share this information with all other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Lake Santee RWWD PWSID# IN5216003
system name *PWSID*